



CAPE ENVIRONMENTAL LABORATORY, L.L.C.

102 North Main • Cape May Court House, NJ 08210

email address: capelab2@gmail.com

Phone: 609-463-0077

Fax: 609-463-8977

D.E.P. Cert. #05679

Client: Cape May County Special Services

Address: 148 Crest Haven Road, Cape May Court House, NJ 08210

Analyzed by: Jason Delp

Analyzed Date: 4/15/22

Analyzed Time: 10:00 AM

Analysis Method: SM-3113B

<u>Field</u>	<u>Sampled</u>	<u>Sample #:</u>	<u>Sample Location</u>	<u>Sample Date:</u>	<u>Sample Time</u>	<u>Sample Received:</u>	<u>Sampled By:</u>	<u>Lead Result(ug/L)</u>	<u>Action Level (ug/L)</u>
65861-	Building								
<u>ID #</u>	1992	1	W's Locker Room-Right Side	4/15/2022	8:17 AM	4/15/2022	Joe Quinn	4.98	15
		2	W's Locker Room-Left Side	4/15/2022	8:17 AM	4/15/2022	Joe Quinn	<2.0	15
		3	M's Locker Room-Right Side	4/15/2022	8:20 AM	4/15/2022	Joe Quinn	10.8	15
		4	M's Locker Room-Left Side	4/15/2022	8:20 AM	4/15/2022	Joe Quinn	<2.0	15
		5	Lap Pool Deck	4/15/2022	8:24 AM	4/15/2022	Joe Quinn	5.84	15
		6	Weight Room Hall-Left Side	4/15/2022	8:26 AM	4/15/2022	Joe Quinn	<2.0	15
		7	Weight Room Hall-Right Side	4/15/2022	8:27 AM	4/15/2022	Joe Quinn	<2.0	15
		8	Women's RR ABC Gym-Right	4/15/2022	8:29 AM	4/15/2022	Joe Quinn	<2.0	15
		9	Women's RR ABC Gym-Left	4/15/2022	8:30 AM	4/15/2022	Joe Quinn	<2.0	15
		10	Mural Area-Left Side	4/15/2022	8:31 AM	4/15/2022	Joe Quinn	<2.0	15
		11	Mural Area-Right Side	4/15/2022	8:31 AM	4/15/2022	Joe Quinn	10.6	15
		12	Sattelite Kitchen	NOT USED	NA	NA	NA	NA	NA
		13	Room 231	4/15/2022	8:36 AM	4/15/2022	Joe Quinn	<2.0	15
		14	231 Restroom	4/15/2022	8:36 AM	4/15/2022	Joe Quinn	<2.0	15

15	Student Cafeteria -Right Side	4/15/2022	8:35 AM	4/15/2022	Joe Quinn	<2.0	15
16	Student Cafeteria -Left Side	4/15/2022	8:37 AM	4/15/2022	Joe Quinn	<2.0	15
17	Nurse-Restroom	4/15/2022	8:36 AM	4/15/2022	Joe Quinn	<2.0	15
18	Nurse-Exam 1(across from RR)	4/15/2022	8:36 AM	4/15/2022	Joe Quinn	<2.0	15
19	Nurse-Exam 1(closest to Nurse)	4/15/2022	8:39 AM	4/15/2022	Joe Quinn	<2.0	15
20	Staff Lounge	4/15/2022	8:39 AM	4/15/2022	Joe Quinn	<2.0	15
21	Main Office Kitchen	4/15/2022	8:40 AM	4/15/2022	Joe Quinn	<2.0	15
22	Room 223 Restroom	4/15/2022	8:41 AM	4/15/2022	Joe Quinn	<2.0	15
23	Room 223 Kitchen	4/15/2022	8:41 AM	4/15/2022	Joe Quinn	<2.0	15
24	Hallway near Room 223-Left Side	4/15/2022	8:43 AM	4/15/2022	Joe Quinn	<2.0	15
25	Hallway near Room 223-Right Side	4/15/2022	8:43 AM	4/15/2022	Joe Quinn	<2.0	15
26	Room 220-Left Side	Not Used	NA	NA	NA	NA	NA
27	Room 220-Right Side	Not Used	NA	NA	NA	NA	NA
28	Room 207-Kitchen	4/15/2022	8:49 AM	4/15/2022	Joe Quinn	<2.0	15
29	Room 207-Restroom	4/15/2022	8:45 AM	4/15/2022	Joe Quinn	<2.0	15
30	Room 214	4/15/2022	9:07 AM	4/15/2022	Joe Quinn	<2.0	15
31	Board of Education Break Room	4/15/2022	8:50 AM	4/15/2022	Joe Quinn	<2.0	15
32	Whittington DayBreak Program Kitchen	4/15/2022	8:51 AM	4/15/2022	Joe Quinn	<2.0	15
33	Hallway Outside WDBP-Left	4/15/2022	8:46 AM	4/15/2022	Joe Quinn	6.11	15
34	Hallway Outside WDBP-Right	4/15/2022	8:56 AM	4/15/2022	Joe Quinn	<2.0	15
35	Boy's Restroom Across from WDBP-Left	4/15/2022	9:00 AM	4/15/2022	Joe Quinn	<2.0	15
36	Boy's Restroom Across from WDBP-Middle	4/15/2022	9:00 AM	4/15/2022	Joe Quinn	<2.0	15
37	Boy's Restroom Across from WCBP-Right	4/15/2022	9:01 AM	4/15/2022	Joe Quinn	<2.0	15
38	Girl's Restroom Across from WDBP-Left	4/15/2022	9:03 AM	4/15/2022	Joe Quinn	<2.0	15
39	Girl's Restroom Across from WDBP-Middle	4/15/2022	9:02 AM	4/15/2022	Joe Quinn	<2.0	15
40	Girl's Restroom Across from WCBP-Right	4/15/2022	9:03 AM	4/15/2022	Joe Quinn	<2.0	15
41	Apple Tree Day Care Center Kitchen -Left Side	4/15/2022	9:05 AM	4/15/2022	Joe Quinn	<2.0	15

42 Apple Tree Day Care Center Kitchen - Right Side 4/15/2022 9:05 AM 4/15/2022 Joe Quinn <2.0 15



CAPE ENVIRONMENTAL LABORATORY, L.L.C.

102 North Main • Cape May Court House, NJ 08210

email address: capelab2@gmail.com

Phone: 609-463-0077

Fax: 609-463-8977

D.E.P. Cert. #05679

Client: Cape May County Special Services

Address: 148 Crest Haven Road, Cape May Court House, NJ 08210

Analyzed by: Jason Delp

Analyzed Date: 4/15/22

Analyzed Time: 10:00 AM

Analysis Method: SM-3113B

<u>Field Sampled ID #</u>	<u>Sample #:</u>	<u>Sample Location</u>	<u>Sample Date:</u>	<u>Sample Time</u>	<u>Sample Received:</u>	<u>Sampled By:</u>	<u>Lead Result(ug/L)</u>	<u>Action Level (ug/L)</u>
65862-Building - 1981	1	Main Kitchen-Boiler Room Wall -Right Side	4/15/2022	9:10 AM	4/15/2022	Joe Quinn	<2.0	15
	2	Main Kitchen-Boiler Room Wall -Left Side	4/15/2022	9:10 AM	4/15/2022	Joe Quinn	<2.0	15
	3	Main Kitchen-Dish Washer	4/15/2022	9:10 AM	4/15/2022	Joe Quinn	<2.0	15
	4	Main Kitchen-Stainless Steel Island Sink	4/15/2022	9:12 AM	4/15/2022	Joe Quinn	<2.0	15
	5	Main Kitchen	4/15/2022	9:12 AM	4/15/2022	Joe Quinn	<2.0	15

6	Staff Dining Room next to Kitchen	4/15/2022	9:13 AM	4/15/2022	Joe Quinn	<2.0	15
7	Water Fountain Cooler-Hall closet to Room 321	4/15/2022	9:10 AM	4/15/2022	Joe Quinn	3.35	15
8	Water Fountain Cooler-Hall closet to Room 323 (New)	NA	NA	NA	NA	NA	NA
9	Water Fountain Cooler-HS Cafeteria-Front	4/15/2022	9:17 AM	4/15/2022	Joe Quinn	9.1	15
10	Water Fountain Cooler-HS Cafeteria-Back	4/15/2022	9:17 AM	4/15/2022	Joe Quinn	2.52	15
11	Back Porch-Café-separate sink	4/15/2022	9:20 AM	4/15/2022	Joe Quinn	<2.0	15
12	Sink in office adjoining Room 326	4/15/2022	9:20 AM	4/15/2022	Joe Quinn	2.13	15
13	Water Fountain Cooler-Hall closet to Room 327	4/15/2022	9:21 AM	4/15/2022	Joe Quinn	***16.5	15
14	Water Fountain Cooler-Hall closet to Room 329	4/15/2022	9:21 AM	4/15/2022	Joe Quinn	14.2	15
15	Water Fountain Cooler-Hall closet to Room 302	4/15/2022	9:25 AM	4/15/2022	Joe Quinn	4.94	15
16	Water Fountain Cooler-Hall closet to Room 304	4/15/2022	9:25 AM	4/15/2022	Joe Quinn	***95.6	
17	Room 305 Classroom Sink	4/15/2022	9:27 AM	4/15/2022	Joe Quinn	2.08	15
18	Cougar Deli-Left Side	NA	NA	NA	NA	NA	NA
19	Cougar Deli-Right Side	NA	NA	NA	NA	NA	NA
20	Room 124 Classroom Sink	4/15/2022	9:27 AM	4/15/2022	Joe Quinn	<2.0	15
21	Room 126 Classroom Sink	4/15/2022	9:31 AM	4/15/2022	Joe Quinn	2.92	15
22	Room 127 Kitchen	4/15/2022	9:31 AM	4/15/2022	Joe Quinn	<2.0	15
23	Water Fountain Cooler-Hall closet to Room 127	4/15/2022	9:33 AM	4/15/2022	Joe Quinn	<2.0	15
24	Water Fountain Cooler-Hall closet to Room 128	4/15/2022	9:41 AM	4/15/2022	Joe Quinn	4.49	15
25	Room 129 Classroom Sink	4/15/2022	9:36 AM	4/15/2022	Joe Quinn	2.71	15
26	Water Fountain Cooler-Hall closet to Room 120(Bottle Fill)	4/15/2022	9:39 AM	4/15/2022	Joe Quinn	<2.0	15
27	Water Fountain Cooler-OA Cafeteria closest to PBX	4/15/2022	9:29 AM	4/15/2022	Joe Quinn	***45.8	15
28	Water Fountain Cooler-OA Cafeteria closest to Kitchen	4/15/2022	9:29 AM	4/15/2022	Joe Quinn	***125	15
29	Sink-OA Nurse Restroom	4/15/2022	9:42 AM	4/15/2022	Joe Quinn	<2.0	15

30	Sink-OA Nurse Treatment Area	4/15/2022	9:47 AM	4/15/2022	Joe Quinn	<2.0	15
31	Sink-Room 103 Restroom	4/15/2022	9:45 AM	4/15/2022	Joe Quinn	<2.0	15
32	Sink-Room 105 Restroom	4/15/2022	9:50 AM	4/15/2022	Joe Quinn	2.59	15
33	Room 105 Classroom Sink	4/15/2022	9:50 AM	4/15/2022	Joe Quinn	<2.0	15
34	Water Fountain Cooler-Hall closet to Room 105	4/15/2022	9:51 AM	4/15/2022	Joe Quinn	***80.1	15
35	Water Fountain Cooler-Hall closet to Room 107	4/15/2022	9:51 AM	4/15/2022	Joe Quinn	***45.5	15
36	Room 104- Classroom Sink	4/15/2022	9:52 AM	4/15/2022	Joe Quinn	<2.0	15
37	Room 106 -Classroom sink	4/15/2022	9:56 AM	4/15/2022	Joe Quinn	<2.0	15
38	Room 107 -Classroom Sink	4/15/2022	9:55 AM	4/15/2022	Joe Quinn	<2.0	15
39	Room 109 -Classroom Sink	4/15/2022	9:57 AM	4/15/2022	Joe Quinn	4.35	15
40	Room 108-Classroom Sink	4/15/2022	9:58 AM	4/15/2022	Joe Quinn	<2.0	15



Tim Delp, Lab Director

