

**Client:** Cape May County Special Services

**Address:** 148 Crest Haven Road, Cape May Court House, NJ 08210

**Sample ID:** 72846

**Analyzed by:** Jason Delp

**Analyzed Date:** 1/3/25

**Analyzed Time:** 1:14 pm

**Analysis Method:** SM-3113B

**72846-  
Building 1992**

Sample #:	Sample Location	Sample Date:	Sample Time	Sample Received:	Sampled By:	Lead Result(u g/L)	Action Level (ug/L)	pH 12/21/24 2:15 pm	TURB
6	Weight Room Hall-Left Side	12/21/2024	7:31 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
7	Weight Room Hall-Right Side	12/21/2024	7:31 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
8	Women's RR ABC Gym-Right	12/21/2024	7:34 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
9	Women's RR ABC Gym-Left	12/21/2024	7:34 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
10	Mural Area-Left Side	12/21/2024	7:35 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
11	Mural Area-Right Side	12/21/2024	7:35 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
13	Room 231	12/21/2024	7:37 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
14	231 Restroom	12/21/2024	7:37 AM	12/21/2024	Tim Delp	8.7	15	<2	<1
15	Student Cafeteria -Right Side	12/21/2024	7:40 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
16	Student Cafeteria -Left Side	12/21/2024	7:40 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
17	Nurse-Restroom	12/21/2024	7:41 AM	12/21/2024	Tim Delp	2.27	15	<2	<1
18	Nurse-Exam 1(across from RR)	12/21/2024	7:41 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
19	Nurse-Exam 1(closest to Nurse)	12/21/2024	7:42 AM	12/21/2024	Tim Delp	2.16	15	<2	<1
20	Staff Lounge	12/21/2024	7:44 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
21	Main Office Kitchen	12/21/2024	7:44 AM	12/21/2024	Tim Delp	2.68	15	<2	<1
22	Room 223 Restroom	12/21/2024	7:48 AM	12/21/2024	Tim Delp	6.26	15	<2	<1
23	Room 223 Kitchen	12/21/2024	7:47 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
24	Hallway near Room 223-Left Side	12/21/2024	7:46 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
25	Hallway near Room 223-Right Side	12/21/2024	7:46 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1

Sample #:	Sample Location	Sample Date:	Sample Time	Sample Received:	Sampled By:	Lead Result(u g/L)	Action Level (ug/L)	pH 12/21/24 2:15 pm	TURB
28	Room 207-Kitchen	12/21/2024	7:52 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
29	Room 207-Restroom	12/21/2024	7:52 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
30	Room 214	12/21/2024	8:01 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
31	Board of Education Break Room	12/21/2024	7:53 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
32	Whittington DayBreak Program Kitchen	12/21/2024	7:54 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
33	Hallway Outside WDBP-Left	12/21/2024	7:56 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
34	Hallway Outside WDBP-Right	12/21/2024	7:56 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
35	Boy's Restroom Across from WDBP-Left	12/21/2024	7:58 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
36	Boy's Restroom Across from WDBP-Middle	12/21/2024	7:58 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
37	Boy's Restroom Across from WCBP-Right	12/21/2024	7:58 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
38	Girl's Restroom Across from WDBP-Left	12/21/2024	8:00 AM	12/21/2024	Tim Delp	4.29	15	<2	<1
39	Girl's Restroom Across from WDBP-Middle	12/21/2024	8:00 AM	12/21/2024	Tim Delp	4.52	15	<2	<1
40	Girl's Restroom Across from WCBP-Right	12/21/2024	8:00 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
41	Apple Tree Day Care Center Kitchen -Left Side	12/21/2024	8:04 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
42	Apple Tree Day Care Center Kitchen -Right Side	12/21/2024	8:04 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
43	Field Reagent Blank	12/21/2024		12/21/2024	Tim Delp	<2.0	15	<2	<1

**Client:** Cape May County Special Services

**Address:** 148 Crest Haven Road, Cape May Court House, NJ 08210

**Sample ID:** 72845

**Analyzed by:** Jason Delp

**Analyzed Date:** 1/3/25

**Analyzed Time:** 1:14 pm

**Analysis Method:** SM-3113B

**72845-  
Building 1981**

Sample #:	Sample Location	Sample Date:	Sample Time	Sample Received:	Sampled By:	Result(u g/L)	Level (ug/L)	12/21/24 2:15 pm	TURB
1	Main Kitchen-Boiler Room Wall -Right Side	12/21/2024	8:13 AM	12/21/2024	Tim Delp	3.01	15	<2	<1
2	Main Kitchen-Boiler Room Wall -Left Side	12/21/2024	8:13 AM	12/21/2024	Tim Delp	4.71	15	<2	<1
3	Main Kitchen-Dish Washer	12/21/2024	8:14 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
4	Main Kitchen- Stainless Steel Island Sink	12/21/2024	8:14 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
5	Main Kitchen	12/21/2024	8:15 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
6	Staff Dining Room next to Kitchen	12/21/2024	8:17 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
7	Water Fountain Cooler-Hall closet to Room 321	12/21/2024	8:19 AM	12/21/2024	Tim Delp	3.23	15	<2	<1
8	Water Fountain Cooler-Hall closet to Room 323 (New)	12/21/2024	8:19 AM	12/21/2024	Tim Delp	<2.0	NA	<2	<1
10	Water Fountain Cooler-HS Cafeteria-Back	12/21/2024	8:21 AM	12/21/2024	Tim Delp	3.99	15	<2	<1
11	Back Porch-Café-separate sink	12/21/2024	8:23 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
12	Sink in office adjoining Room 326	12/21/2024	8:25 AM	12/21/2024	Tim Delp	***17.2	15	<2	<1
14	closet to Room 329	12/21/2024	8:25 AM	12/21/2024	Tim Delp	5.24	15	<2	<1
15	Water Fountain Cooler-Hall closet to Room 302	12/21/2024	8:27 AM	12/21/2024	Tim Delp	4.25	15	<2	<1
17	Room 305 Classroom Sink	12/21/2024	8:29 AM	12/21/2024	Tim Delp	***16.9	15	<2	<1
20	Room 124 Classroom Sink	12/21/2024	8:32 AM	12/21/2024	Tim Delp	2.6	15	<2	<1
21	Room 126 Classroom Sink	12/21/2024	8:33 AM	12/21/2024	Tim Delp	3.02	15	<2	<1
22	Room 127 Kitchen	12/21/2024	8:34 AM	12/21/2024	Tim Delp	2.43	15	<2	<1
23	Water Fountain Cooler-Hall closet to Room 127	12/21/2024	8:34 AM	12/21/2024	Tim Delp	3.74	15	<2	<1

Sample #:	Sample Location	Sample Date:	Sample Time	Sample Received:	Sampled By:	Lead Result(u g/L)	Action Level (ug/L)	pH 12/21/24 2:15 pm	TURB
24	Water Fountain Cooler-Hall closet to Room 128	12/21/2024	8:35 AM	12/21/2024	Tim Delp	4.59	15	<2	<1
25	Room 129 Classroom Sink	12/21/2024	8:36 AM	12/21/2024	Tim Delp	7.62	15	<2	<1
26	Water Fountain Cooler-Hall closet to Room 120(Bottle Fill)	12/21/2024	8:36 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
27	Water Fountain Cooler-OA Cafeteria closest to PBX	12/21/2024	8:37 AM	12/21/2024	Tim Delp	6.57	15	<2	<1
28	Water Fountain Cooler-OA Cafeteria closest to Kitchen	12/21/2024	8:37 AM	12/21/2024	Tim Delp	2.44	15	<2	<1
29	Sink-OA Nurse Restroom	12/21/2024	8:39 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
30	Sink-OA Nurse Treatment Area	12/21/2024	8:39 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
31	Sink-Room 103 Restroom	12/21/2024	8:41 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
32	Sink-Room 105 Restroom	12/21/2024	8:42 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
33	Room 105 Classroom Sink	12/21/2024	8:42 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
34	Water Fountain Cooler-Hall closet to Room 105	12/21/2024	N/A	12/21/2024	Tim Delp	<2.0	15	<2	<1
35	Water Fountain Cooler-Hall closet to Room 107	12/21/2024	8:43 AM	12/21/2024	Tim Delp	9.36	15	<2	<1
36	Room 104- Classroom Sink	12/21/2024	8:44 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
37	Room 106 -Classroom sink	12/21/2024	8:46 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
38	Room 107 -Classroom Sink	12/21/2024	8:46 AM	12/21/2024	Tim Delp	5.62	15	<2	<1
39	Room 109 -Classroom Sink	12/21/2024	8:47 AM	12/21/2024	Tim Delp	3.32	15	<2	<1
40	Room 108-Classroom Sink	12/21/2024	8:48 AM	12/21/2024	Tim Delp	4.08	15	<2	<1
41	Ice Machine	12/21/2024	8:16 AM	12/21/2024	Tim Delp	<2.0	15	<2	<1
42	Field Reagent Blank	12/21/2024		12/21/2024	Tim Delp	<2.0	15	<2	<1

*Tim Delp*

---

Tim Delp  
Lab Director